



Certificate of Compliance

Certificate: 70051609 (205078)

Master Contract: 205078

Project: 70051609

Date Issued: 2016-08-05

Issued to: Analog Devices Inc.
804 Woburn St
Wilmington, Massachusetts 01887-3462
USA

Attention: Mark Cantrell

The products listed below are eligible to bear the CSA Mark shown with adjacent indicator ▲



Issued by: Martin Buchanan
Martin Buchanan, P. Eng.

PRODUCTS

CLASS - C907330 - ELECTRONIC COMPONENTS-Optoisolators

CLASS - C907330 - ELECTRONIC COMPONENTS-Optoisolators

Component Acceptance of Optoisolator Like Magnetic Coupling Devices:

Device (SOIC 16N R package)	Ratings		Standard/Notice and Clauses	Internal		External
	kV	°C		Creepage (mm)	Dist Thru (mm)	Creep/Clear (mm)
ADuM13xyzBRZ ADuM14xyzBRZ	3.0	125	CSA CA5A, 14-13 Tbl 35, 6.2.1.1, 6.2.1.1/6.2.10, 6.8.1.1 60950-1-07+A1+A2 2.10.3.3, 2.10.4.2, 2.10.4.3, 2.10.5.4a, 2.10.11, 4.5.2, 5.2 61010-1-12+A1 K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10 60601-1:14 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7 IEC 60950-1 2nd Ed.,+A1+A2 2.10.3.3, 2.10.4.2, 2.10.4.3, 2.10.5.4a, 2.10.11, 4.5.2, 5.2	-	-	4.0



Certificate: 70051609
Project: 70051609

Master Contract: 205078
Date Issued: 2016-08-05

Device (SOIC 16N R package)	Ratings		Standard/Notice and Clauses	Internal		External
	kV	°C		Creepage (mm)	Dist Thru (mm)	Creep/Clear (mm)
			61010-1 3 rd Ed A1 K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10 60601-1 Ed.3+A1 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7 EN 60950-1:2006+A1+A12+A2 2.10.3.3, 2.10.4.2, 2.10.4.3, 2.10.5.4a, 2.10.11, 4.5.2, 5.2			

where x is 0, 1 or 2 for the number of reverse channels, y is D for input disable or E for output enable, z is for fail safe output state with 0 for low and 1 for high and Z, if used, indicates the lead-free version. Suffix EP at the end of the base part number indicates lower extended temperature capability to -55C with a NiPdAu lead finish. Further suffix letters or digits differentiate shipping package formats.

Notes:

1. These devices meet basic insulation requirements for 400Vrms for CSA 60950-1-07+A1+A2 and IEC 60950-1 2nd Ed.+A1+A2.
2. These devices meet reinforced insulation requirements for 200Vrms for CSA 60950-1-07+A1+A2 and IEC 60950-1 2nd Ed.+A1+A2. (pollution degree 2, material group III)
3. For CSA 61010-1-12+A1 and IEC 61010-1 3rd Ed. for 300Vrms, overvoltage category III for basic insulation and 150Vrms, overvoltage category IV for basic insulation, the devices meet clauses K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6 and 10. The risk management process is not applicable to these clauses. (pollution degree 2, material group III)
4. For CSA 60601-1:14 and IEC60601-1 Ed.3+A1 for 1 MOPP for 250Vrms, the devices meet clauses 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7. The risk management process is not applicable to these clauses.
4. Case material: 575Vrms with erosion depth 0.079mm, meets material group II.
5. Evaluated by thermal cycling and other tests for a temperature rating of 125C.
6. The creepage and clearance has been evaluated for altitudes ≤ 2000m, in pollution degree 2 and overvoltage category II except where specified above. (pollution degree 2, material group III).

These devices are Component Accepted as components for use in other Certified equipment where the suitability of the combination shall be determined by investigation in the final application.

APPLICABLE REQUIREMENTS

- Component Acceptance Notice 5A (CA 5A) - Announcement of Extension of the Component Acceptance Service for Optocouplers and Related Devices
- CAN/CSA-C22.2 No 14-13 - Industrial Control Equipment
- CAN/CSA-C22.2 No 60950-1-07+A1+A2 - Information Technology Equipment - Safety - Part 1: General Requirements (Bi-national Standard, with UL 60950-1)
- IEC 60950-1 2nd Ed.+A1+A2 - Information Technology Equipment - Safety - Part 1: General Requirements
- EN 60950-1:2006+A1+A12+A2 - Information Technology Equipment - Safety - Part 1: General Requirements



Certificate: 70051609

Project: 70051609

Master Contract: 205078

Date Issued: 2016-08-05

Clauses K.3, K.4, 6.7.1.3, 6.7.2.2.2 A.17, K.6x1.6, K.7x1.6, 10

of

CAN/CSA-C22.2 No. 61010-1-12+A1 2015 - Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements (Tri-national standard, with UL 61010-1 Ed. 3 and ANSI/ISA-61010-1 (82.02.01))

and

IEC 61010-1:2010 3rd Ed. - Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use - Part 1: General Requirements

Clauses 8.5.5.1, 8.8.2, 8.8.3x1.6, 8.9.3.2, 8.9.3.4, 8.9.1.15, 8.9.1.7

of

CAN/CSA C22.2 60601-1:14 - Medical Electrical Equipment Part 1: General requirements for basic safety and general performance (Adopted IEC60601-1:2005 Edition 3.0 +Amendment 1, 2012-07, MOD)

and

IEC60601-1:2005 Ed 3.0+A1 - Medical Electrical Equipment Part 1: General requirements for basic safety and general performance



Supplement to Certificate of Compliance

Certificate: 70051609 (205078)

Master Contract: 205078

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70051609	2016-08-05	Original Component Acceptance